

**CHHATTISGARH STATE POWER TRANSMISSION CO. LTD.**

(A Govt. of Chhattisgarh Undertaking)

OFFICE OF S.E. (T&C), Bijli Nagar, BHILAI-3, Pin: 490021  
DIST. DURG (CG) Ph./Fax No. 0788-2281561, Email: [setc.bhl@hotmail.com](mailto:setc.bhl@hotmail.com)

No. 10-70/T-

/ 970

/BHILAI, DATE: 127 AUG 2014

To,

M/s. Jyoti Limited,  
Switch Gear Division,  
J/44-59, BIDC, Garwa  
Vadodara- 390016

Sub: **Performance of Distance Protection Relay (Make Protecta-Hungary).**

Ref: EE MRT Dn. Bhilai's letter No.211 dated 17/07/14.

The Distance Protection Relay provided by you was installed on 132KV Bhilai -I feeder at 132KV S/S Ruabandha on dated 13/06/16. During the entire period of operation from the date of installation till date the relay has successfully operated on line faults. The details of relay are:

Make: Protecta Hungary (Euro Prot+)  
Type: DTVA  
Platform: IED -EP+  
Config: E1- Line - 4  
S. No.: 130164

Forwarded for information.

Thanking You



**SUPERINTENDING ENGINEER  
(T&C) CIRCLE CSPTCL BHILAI**

Copy to:-

1. The Executive Engineer MRT Dn., CSPTCL, Bhilai.